







### Please Note

The meter is intended to be installed in a Mechanical Environment 'M1', with Shock and Vibrations of low significance, as per 2004/22/EC Directive. The meter is intended to be installed in Electromagnetic Environment 'E2', as per 2004/22/EC Directive.

Installation of this device may only be performed by qualified personnel.

#### Technical support

In case you have any questions about our product, please contact Rayleigh Instruments on 01245 428500.

#### Attention

The Meter housing is sealed. Warranty is void if the seal is broken or removed





RAYLEIGH INSTRUMENTS LIMITED
Cutlers Road
South Woodham Ferrers
Chelmsford
Essex
CM3 5WA
UK

RI-122-100-P



#### Rayleigh Instruments Limited

#### **DECLARATION OF CONFORMITY**

According to Directive 2004/22/EC

Report Ref: SHES1207001819MI

Issued 27<sup>th</sup> November 2012

Compiled by: SGS

Product : Single Phase Energy Meter

Model No. : RI-122-100-P

Rating: 100A

Output : SO. Pulse

The test sample has been tested in accordance with the requirements of

Directive 2004/22/EC as stated on Certificate 0120/SGS0140

The technical documentation required to demonstrate that the products meet the requirements of the above EU directives has been compiled and is available for inspection by relevant enforcement authorities.



Approved by/Date 1/10/14

Rayleigh Instruments Limited
Raytel House, Cutlers Road, South Woodham Ferrers,
Essex, CM3 5WA
Tel. 01245428500 Fax 01245428559
Web. www.rayleigh.co.uk

## RI-122-100-P 230V 5(100)A LCD

# Three Phase Energy Meter – 100A Direct MID With Pulsed Output

5 (100)A	
3 x 230 / 400V ± 20%	
1000 Impulse / KWh	
В	
50Hz ± 10%	
9. <b>9</b> KWh LCD	
0	
e / alue 95%	
EN50470-3	
1000 lmp/kWh RL =1 Wh/lmp RA= 1Wh/lmp S0-Standard DIN 43864	
30~ 80mS	
0.05-0.25KHz	
50mm <sup>2</sup>	



